



HIMACHAL PRADESH  
PUBLIC WORKS DEPARTMENT

Office Phone No.01894-263035

Mail ID:ee-baij-hp@nic.in

NO.PWD/BN/WA/Building Safety/2022-23/ 20692-93 Dated: 07-03-2023

To

The Principal,  
Parmarth International School Baijnath ,  
V.P.O. Tehsil Baijnath Distt. Kangra HP.


Subject:-

Regarding building Safety certificate.


The building safety certificate of your school is enclosed herewith for further necessary action.

The above certificate is issue on the basis of document supplied by you and visual inspection of Assistant Engineer HP.PWD., Sub-Division Baijnath. This certificate is valid for session 2023-24.

DA/Safety Certificate.

  
Executive Engineer,  
Baijnath Division,  
HP. PWD, Baijnath.

Copy forwarded to the Assistant Engineer HP.PWD., Sub-Division Baijnath for information and necessary action w.r.t. his office letter No. 3256 Dated 03.03.2023.

  
Executive Engineer,  
Baijnath Division,  
HP. PWD, Baijnath.



Office Phone No. 01894-262327  
[aehppwdbajnath17@gmail.com](mailto:aehppwdbajnath17@gmail.com)

Himachal Pradesh  
Public Works Department

## Building Safety Certificate


The school Building of **Parmarth International School Baijnath Tehsil Baijnath Distt. Kangra (HP)** was inspected by the Junior Engineer concerned on dated 03-03.2023. It has been observed that no earthquake resistant provisions have been adopted for this building and no structural drawings approved by the competent Government certified Engineer have been produced at the time of inspection. Moreover no assistance was taken from PWD for construction of this building. This structure is a non-engineered structure. Hence the structural safety of this building cannot be ensured specifically from earthquake resistant point of view. This department will not be responsible for any type of loss of life and property etc., if this structure fails under any circumstances.

However, as per visual inspection the building has been found safe at present only. No Officer/Official of this office will attend plea in any Hon'ble Court of Law in case of any dispute.

**The school building safety certificate is valid for one year after the issue of certificate.**

Place: - Bajnath.  
Dated: - 03-03.2023

  
Junior Engineer  
Bajnath Section  
HPPWD Baijnath

  
Assistant Engineer  
Bajnath Sub-Division  
HPPWD, Baijnath

  
Executive Engineer,  
Bajnath Division,  
HPPWD. Baijnath